

Evidence of Performance

Air permeability, Watertightness, Resistance to wind load



Test Report

No. 12-002318-PR01

(PB-A01-02-en-01)

Client Arbor Ahsap Yapı Elemanları
Atatürk bulvarı Köstemir yolu
No:74 Silivri
Istanbul
Turkey

Product Tilt and turn window

Designation System designation: 68S

Performance-relevant product details Material: Wood (Scots pine)

Overall dimensions (W x H) 1,230 mm x 1,480 mm

Special features

Basis

EN 14351-1:2006+A1:2010

Test standard/s:

EN 1026:2000-06

EN 1027:2000-06

EN 12046-1:2003-11

EN 12211:2000-06

EN 14609:2004-06

Correspond/s to the national standard/s (e.g. DIN EN)

Representation



Results

Air permeability according to EN 12207:1999-11



Class 4

Watertightness according to EN 12208:1999-11



Class 9A

Resistance to wind load according to EN 12210:1999-11/AC:2002-08



Class C3 / B3

Instructions for use

The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. Observe the specifications set out by the applicable product standard.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 18 pages.

ift Rosenheim

03.09.2012

Robert Kolacny, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Building Components

Rolf Schnitzler, Dipl.-Ing. (FH)
Operating Product Officer
Building Components